



January 17, 2023

Project Change No.: 4
Heapy Change No.: 4
Project: GCCC South Facility Air Handler Replacement
Heapy Project No. 2022-07014

Addendum 4 Description:

Drawing Changes

None

Specification Changes

1. 23 05 01 BASIC HVAC REQUIREMENTS – Section 1.2, added Part C as follows:
 - C. Alternate#3 – Photo-catalytic oxidation system for air handling units AC-H-1, AC-H-2, AC-H-3, AC-H-4.
The base bid work includes a blank section in air handling units AC-H-1, AC-H-2, AC-H-3, AC-H-4, where a photo-catalytic oxidation air cleaning system could be installed. The base bid work does not include equipment, installation, or electrical power of the photo-catalytic air cleaning system in air handling units AC-H-1, AC-H-2, AC-H-3, AC-H-4.

Each bidder is requested to state the addition in cost to provide all HVAC and Electrical work for equipment and installation of a photo-catalytic oxidation system for each air handling unit AC-H-1, AC-H-2, AC-H-3, AC-H-4. The photo-catalytic oxidation system can be either factory installed by the air handling unit manufacturer or field installed by the HVAC contractor.